

Facility Summary in TREASURE County in the City of HYSHAM

Location: FARMERS UNION OIL CO HYSHAM
121 ELLIOT AVE
HYSHAM, MT 59038 TREASURE

Sys Fac ID: 52-01905

Last Inspected On: 12/2/2014

Operating Permit Renewal Date: 2/27/2018

Contact: Bill Haggerty, (406) 342-5221

Owners/Operators: Farmers Union Oil Co, Owner (406)-967-3100 PO BOX 309
WORDEN MT 59088-0309

Scott Black, UST Class A Operator
Shawn Hedges, UST Class B Operator
Sheryl Warren, UST Class B Operator
Scott Black, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
3	25	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3144			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Gasoline		12/2/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					
4	25	7/1/1990	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3145			None	None	Yes
Currently in Use			Not Required	Safe Suction	Galvanic
Diesel		12/2/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Deferred	
1,000					

Facility Summary in TREASURE County in the City of HYSHAM

Location: FRIENDLY CORNER
718 ELLIOT AVE
HYSHAM, MT 59038 TREASURE
Contact: Shelly Thorwer, (406) 342-5888

Sys Fac ID: 52-06316
Last Inspected On: 6/25/2015
Operating Permit Renewal Date: 9/29/2018

Owners/Operators: Cross Petroleum Services Billings, Owner (406)-252-5519 PO BOX 1078
BILLINGS MT 59103-1078
Gregory Cross, UST Class A Operator
Timothy Fife, UST Class A Operator
RJ Serpe, UST Class A Operator
RJ Serpe, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	36	8/1/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1405			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		3/24/2012	TLS-350/Gilbarco EMC , Veeder Root		
2	36	8/1/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1406			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Diesel		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000		4/1/2012	TLS-350/Gilbarco EMC , Veeder Root		
3	36	8/1/1979	Bare Steel	Fiberglass Reinforced Plastic	High Level Alarm
1407			Lined Interior/Impressed Current	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Impressed Current
Gasoline		6/25/2015	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
3,000		4/5/2012	TLS-350/Gilbarco EMC , Veeder Root		